

**AN ORDINANCE OF ANTRIM TOWNSHIP,  
FRANKLIN COUNTY, PENNSYLVANIA, NO. 354 OF 2020**

**AN ORDINANCE OF THE BOARD OF SUPERVISORS OF THE TOWNSHIP OF ANTRIM, FRANKLIN COUNTY, PENNSYLVANIA, AMENDING CHAPTER 111 ENTITLED "PRETREATMENT".**

**WHEREAS**, the Township of Antrim currently has pretreatment regulations as set forth in the Code of the Township of Antrim, Pennsylvania; and

**WHEREAS**, the Antrim Township Board of Supervisors desire to amend the Code of the Township of Antrim in order to comply with State and Federal Laws and Regulations; and

**WHEREAS**, the amendment of Chapter 111 of the Code of the Township of Antrim is necessary to assure continuity of wastewater treatment, help prevent violation of the Authority's NPDES permit and protect the system from damage; and

**WHEREAS**, the amendment of Chapter 111 of the Code of the Township of Antrim is necessary for the protection, benefit and preservation of the health, safety and welfare of the inhabitants of the Township; and

**WHEREAS**, authority is vested in the Township of Antrim to require connection to and establish rules and regulations for sewer systems within the Township by Section 2501 et seq. of the Second-Class Township Code (53 P.S. 67501 et seq.) and other State and Federal Laws.

**NOW, THEREFORE, BE IT ENACTED AND ORDAINED**, by the Board of Supervisors of the Township of Antrim as follows:

**SECTION I:** The Code of the Township of Antrim, Franklin County, Pennsylvania Chapter 111-8 entitled "Local Limits" is hereby amended by deleting Schedule A under subsection B in its entirety and replacing it with a new Schedule A which is attached hereto and incorporated herein by reference. Subsection B shall remain as written.

**SECTION II:** Effective Date. This Ordinance shall be in full force and effect immediately following its passage, approval, and publication, in accordance with the law.

**SECTION III:** Conflict with other Township Regulations. All other Township regulations as set forth in the Code of the Township of Antrim are hereby repealed if their requirements are less stringent then the requirements as set forth in this ordinance. However, if the requirements are more stringent then the requirements as set forth in this ordinance, then they shall continue in full force and effect. In other words, the more stringent requirement shall apply.


**SECTION IV:** Severability. If any Article, Section, or provision of this Ordinance should be decided by the Courts to be unconstitutional or invalid, such decision shall not affect the validity of this Ordinance as a whole or any part thereof other than the part so

decided to be unconstitutional or invalid.




**ENACTED** by the Board of Supervisors of the Township of Antrim at its regular meeting the 25 day of February, 2020.


Attest:

Supervisors of Antrim Township

  
Jennifer Becknell, Secretary

\_\_\_\_\_  
Pat Heraty, Chairman

  
\_\_\_\_\_  
  
\_\_\_\_\_  
  
\_\_\_\_\_

  
\_\_\_\_\_

**Schedule A**  
**Antrim Township Local Limits**  
**AKA Maximum Allowable Industrial Loadings (MAIL)**

The following Maximum Allowable Industrial Loadings (MAILs) are developed to protect against pass through and interference, and to protect sludge quality. Individual limitations may be allocated to the Industrial Users as needed through Wastewater Discharge Permits issued to the Industrial Users in accordance with Article IV and Article V of Chapter 111. The following limits apply at the point where the wastewater is discharged to the POTW.

<b>Parameter</b>	<b>Daily Maximum MAIL<sup>1</sup>, Lbs/Day</b>
Arsenic	0.2786
BOD	1997
Cadmium	0.0786
Chloride	402
Chromium Tot	1.218
Chromium Hex	3.396
Copper	1.028
Cyanide	0.5904
Lead	0.4374
Manganese	21.47
Mercury	0.0162
Molybdenum	0.3152
Nickel	1.212
Phenol	17.34
Phosphorus	58.09
Selenium	0.559
Silver	0.8707
TN	214
TSS	1110
Zinc	1.160
<sup>1</sup> MAIL is defined as the Maximum Allowable Industrial Loading.	