

**WILLISTOWN TOWNSHIP  
CHESTER COUNTY, PENNSYLVANIA**

**ORDINANCE NO. 3 of 2024**

**AN ORDINANCE AMENDING CHAPTER 105 OF THE CODE OF  
ORDINANCES OF WILLISTOWN TOWNSHIP, GOVERNING SPECIFIC  
DISCHARGE PROHIBITIONS INTO WASTEWATER COLLECTION  
SYSTEMS**

**BE IT AND IT IS HEREBY ENACTED** by the Board of Supervisors of Willistown Township, Chester County, as follows:

**Section 1.** The Code of the Township of Willistown, Chapter 105, Section 32.B (5) is hereby amended to read as follows:

Wastes that exceed any of the following concentrations in a discharge to the process stream of the treatment plant from a connected user as sewage or Tier I waste or from a nonconnected discharge (through a licensed waste hauler) as a Tier I waste, as a daily composite sample or grab sample:

**Tier I Limits:**

Arsenic (total)	0.04	mg/L
Cadmium (total)	0.09	mg/L
Chromium (total)	4.00	mg/L
Copper (total)	1.00	mg/L
Cyanide (total)	0.26	mg/L
Lead (total)	0.10	mg/L
Mercury (total)	0.005	mg/L
Molybdenum (total)	0.50	mg/L
Nickel (total)	0.90	mg/L
Selenium (total)	0.50	mg/L
Silver (total)	0.08	mg/L
Zinc (total)	1.00	mg/L

**Section 2.** The Code of the Township of Willistown, Chapter 105, Section 32.B (6) is hereby amended to read as follows:

Wastes that exceed any of the following concentrations in a discharge to the septage discharge station of the treatment plant from a nonconnected discharge (through a licensed waste hauler) as a Tier II waste in a grab sample or daily composite sample:

**Tier II Limits:**

Arsenic (total)	2.50	mg/L
Cadmium (total)	0.50	mg/L
Chromium (total)	21.00	mg/L
Copper (total)	22.00	mg/L

Cyanide (total)	0.26	mg/L
Lead (total)	18.00	mg/L
Mercury (total)	0.04	mg/L
Molybdenum (total)	5.00	mg/L
Nickel (total)	5.00	mg/L
Selenium (total)	4.00	mg/L
Silver (total)	5.00	mg/L
Zinc (total)	95.00	mg/L

**Section 3.** This Ordinance shall be effective five (5) days from the date of enactment.

ENACTED and ORDAINED this 22nd day of April, 2024.


**BOARD OF SUPERVISORS  
WILLISTOWN TOWNSHIP**



**Robert T. Lange, Chair**



**William R. Shoemaker, Vice Chair**



**Molly H.B. Perrin, Member**

**ATTEST:**

  
**Shanna Lodge, Manager**