

AN ORDINANCE AMENDING SECTION 710.020 OF CHAPTER 710 WATER REGULATIONS OF THE TOWN CODE.

NOW, THEREFORE, BE IT ORDAINED BY THE COUNCIL OF THE TOWN OF CARROLLTON as follows:

Section 1: Chapter 710, Article 1. Lead Ban for Public and Private Drinking Water, of the Town Code of the Town of Carrollton, Missouri is amended as follows:

Section 710.020, the definition of “Lead Free” is amended to state
“Lead free” means:

A. In General.

- 1) When used with respect to solder and flux, refers to solders and flux containing not more than 0.2 percent (0.2%) lead; and
- 2) When used with respect to pipes and pipe fittings, refers to pipes and pipe fittings containing not more than 0.25 percent (0.25%) lead.

B. Calculation

The weighted average lead content of a pipe, pipe fitting, plumbing fitting, or fixture shall be calculated by using the following formula: For each wetted component, the percentage of lead in the component shall be multiplied by the ratio of the wetted surface area of that component to the total wetted surface area of the entire product to arrive at the weighted percentage of lead of the component. The weighted percentage of lead of each wetted component shall be added together, and the sum of these weighted percentages shall constitute the weighted average lead content of the product. The lead content of the material used to produce wetted components shall be used to determine compliance with paragraph (A)(2). For lead content of materials that are provided as a range, the maximum content of the range shall be used.

Section 710.020 is amended to add a new definition as follows:

“Exemptions” means:

- (A) leaded joints necessary for the repair of cast iron pipes.
- (B) pipes, pipe fittings, plumbing fittings, or fixtures, including backflow preventers, that are used exclusively for non-potable services such as manufacturing, industrial processing, irrigation, outdoor watering, or any other uses where the water is not anticipated to be used for human consumption; or
- (C) toilets, bidets, urinals, fill valves, flush-o-meter valves, tub fillers, shower valves, service saddles, or water distribution main gate valves that are 2 inches in diameter or larger.

Section 2: The portions of this Ordinance shall be severable. In the event that any portion of this Ordinance is found by a court of competent jurisdiction to be invalid, the remaining portions of this Ordinance are valid, unless the court finds the valid portions of this Ordinance are so essential and

inseparably connected with and dependent upon the void portion that it cannot be presumed that the City Council would have enacted the valid portions without the invalid one, or unless the court finds that the valid portions standing alone are incomplete and are incapable of being executed in accordance with the legislative intent.

Section 3: This ordinance repeals any prior ordinance or parts of any prior ordinance that might be in conflict herewith.

Section 4. It is the intent of the Town Council that this Ordinance be made a part of the City Code and such inclusion shall have the same force and effect as if the ordinance had been included in the original code at the time of its adoption by the Town Council.

Section 5: This ordinance shall be in full force and effect from and after the date of its passage and approval.

A copy of this Ordinance has been made available for public inspection prior to its adoption by the Council and this bill was read by title in the open meeting two times prior to its final passage.

PASSED AND APPROVED THIS 20th DAY OF MAY 2024.


TOWN OF CARROLLTON, MISSOURI



~~Susan Bliss, Mayor~~

Mayor Pro Tempore

ATTEST:



Dana Reimer, City Clerk