

TOWNSHIP OF COLLIER

ORDINANCE NO. 733

AN ORDINANCE OF THE TOWNSHIP OF COLLIER, AMENDING THE TOWNSHIP CODE OF ORDINANCES, CHAPTER SD260, SANITARY SEWER CONSTRUCTION, PART 23, INSPECTION OF WORK, TO ADD PROVISIONS REQUIRING CCTV INSPECTION OF NEWLY CONSTRUCTED SEWERS AND MAINTENANCE STRUCTURES

WHEREAS, the Township of Collier ("Township") wishes to ensure that all newly constructed mainline sewers are constructed without defect; and

WHEREAS, to the Township has determined that the best way to confirm the construction meets all Township requirements is through Closed Circuit Televising.

I. NOW THEREFORE, the Board of Commissioners of Collier Township does ordain that Chapter SD260 of the Township Code of Ordinances is amended by revising Part 23, Inspection of Work, to add an additional subsection "F" which shall read as follows:

F. All newly constructed mainline sewers, maintenance structures, and appurtenances must be inspected by Closed Circuit Televising (CCTV) to ensure the pipe is without any construction defects, has no internal flow obstruction and has been constructed as per its approved design drawings. The inspection shall verify the information provided with the 'As-Built' drawings. All information shall be submitted to the Collier Township Sewer Department (CTSD).

The CCTV inspections and reports are required to be completed, submitted and approved by the Township prior to acceptance of sewer assets. The inspection must be NASSCO certified and done to the satisfaction of the Township Engineer. This includes, but is not limited to, properly cleaning the line segments, removing any debris, ensuring pipe diameters, a full length MH-MH inspection, inspection of any wye fittings, and submission of the material in the proper formats. All defects identified by the inspection in the initial CCTV survey must be rectified, at no cost to the Township, and resurveyed for final acceptance. Footage of the initial CCTV survey where defects occurred must be attached to the final CCTV inspection report submitted to the CTSD for comparison. The Township Engineer shall have the final determination on completeness. CTSD reserves the right to reject any inspection deemed incomplete. CTSD also reserves the right to observe any CCTV inspection and must be notified when the inspections commence.

Testing of sewer assets as per the CTSD guidelines and standard testing procedures for pressure and gravity pipes and maintenance structures must be conducted prior to final CCTV inspection.

- II. This Ordinance shall be effective upon adoption.
- III. Should any part or provision of this Ordinance be declared invalid by a court of competent jurisdiction, it is the intention of the Board of Commissioners that all remaining parts and provisions of this Ordinance shall be in effect to the full extent permitted by law.
- IV. Any ordinance or resolution inconsistent with this ordinance is repealed to the extent of such inconsistency.

This Ordinance adopted by the Board of Commissioners of Collier Township at a duly assembled public meeting held this 12th day of February, 2024.

ATTEST:

Valerie A. Salla
Valerie A. Salla, Township Secretary

TOWNSHIP OF COLLIER

By: Wayne M. Chiurazzi
Wayne M. Chiurazzi, President
Board of Commissioners

Recording Certification. The undersigned certifies that this Ordinance was recorded in the Collier Township Ordinance Book on February 13, 2024.

0165

Valerie A. Salla
Valerie A. Salla, Township Secretary

