

ORDINANCE 2024-03

**BOROUGH OF DOWNINGTOWN
CHESTER COUNTY, PENNSYLVANIA**

AN ORDINANCE AMENDING THE CODE OF THE BOROUGH OF DOWNINGTOWN, AS AMENDED, BY AMENDING CHAPTER 235, "SEWERS", SECTION 235-23.D, TO ADOPT REVISED DISCHARGE LIMITATIONS FOR SPECIFIC WASTES OR POLLUTANTS DISCHARGED TO THE DOWNINGTOWN REGIONAL WATER POLLUTION CONTROL CENTER.

AND NOW, on this 10th day of July, 2024 it is hereby enacted and ordained by the Borough Council of Downingtown, Chester County, Pennsylvania, that:

SECTION 1. Exhibit 1 to Section 235-23.D of the Borough Code, imposing local discharge limits of specific pollutants for industrial users, is hereby amended to institute the following discharge limits:

EXHIBIT 1

LOCAL DISCHARGE LIMITS

<u>POLLUTANT</u>	<u>END OF PIPE DISCHARGE LIMIT (mg/L)</u>
Cadmium	0.03
Chromium	1.32
Copper	1.42
Cyanide, Free	0.57
Lead	0.14
Mercury	0.002
Nickel	1.83
Phenols	0.12
Silver	0.05
Zinc	2.18

SECTION 2. Applicability. The provisions hereof shall supersede any ordinances or parts of ordinances which are inconsistent herewith.


SECTION 3. Severability. If any provision, sentence, clause, section or part of this ordinance is for any reason found to be unconstitutional, illegal or invalid, such unconstitutionality, illegality or invalidity shall not affect or impair any of the remaining provisions, sentences, clauses, sections or parts hereof. It is hereby declared as the intent of the Borough Council that this Ordinance would have been adopted had such unconstitutional, illegal or invalid provision, sentence, clause, section or part thereof not been included herein.

SECTION 4. Effective Date. This Ordinance shall become effective five (5) days from enactment.


ENACTED AND ORDAINED this 10th day of July, 2024 by the Borough Council of Downingtown.


ATTEST:

By:


Jeff Smith, Manager

BOROUGH OF DOWNINGTOWN


Alex Rakoff, Council President


Phil Dague, Mayor