EASTTOWN TOWNSHIP CHESTER COUNTY, PENNSYLVANIA

ORDINANCE NO. 463-24

AN ORDINANCE AMENDING THE CODE OF THE TOWNSHIP OF EASTTOWN, AS AMENDED, AT CHAPTER 345, ENTITLED "SEWERS AND SEWAGE DISPOSAL," BY AMENDING AT SECTION 345-36 TO REVISE TIER I AND II LIMITS

BE IT ENACTED AND ORDAINED, by the Board of Supervisors of Easttown Township, Chester County, Pennsylvania that the Easttown Township Code, as amended, shall be further amended as follows:

SECTION 1. Chapter 345, "Sewers and Sewage Disposal," Article IV, "Wastewater Discharges," §345-36.E shall hereby be amended by interlineations below, with underlined interlineations indicating insertion of language and strikethrough interlineations indicating deletion of language:

E. Wastes that exceed any of the following concentrations in a discharge to the process stream of the treatment plant from a connected user as sewage or Tier I waste or from a nonconnected discharge (through a licensed waste hauler) as a Tier I waste in a daily composite sample or grab sample:

| | Tier I Limits | |
|-----------------------|-------------------------|---------------------------|
| Parameter | Limitation | Units |
| Arsenic (total) | 0.04 | mg/L |
| Cadmium (total) | 0.09 | mg/L |
| Chromium (total) | <u>6.00</u> <u>4.00</u> | mg/L |
| Chromium (hexavalent) | 1.00 | mg/L |
| Copper (total) | 1.00 | mg/L |
| Cyanide (total) | 0.26 | mg/L |
| Lead (total) | 0.10 | mg/L |
| Mercury (total) | $0.02 \ 0.005$ | mg/L |
| Molybdenum (total) | <u>0.50</u> | $\underline{mg/L}$ |
| Nickel (total) | 0.90 | mg/L |
| Selenium (total) | <u>0.50</u> | $\underline{\text{mg/L}}$ |
| Silver (total) | 0.08 | mg/L |
| Zinc (total) | 1.00 | mg/L |
| PCBs (total) | ND (not detectable) | mg/L |

SECTION 2. Chapter 345, "Sewers and Sewage Disposal," Article IV, "Wastewater Discharges," §345-36.F shall hereby be amended by interlineations below, with underlined interlineations indicating insertion of language and strikethrough interlineations indicating

deletion of language:

F. Wastes that exceed any of the following concentrations in a discharge to the septage discharge station of the treatment plant from a nonconnected discharge (through a licensed waste hauler) as a Tier II waste in a grab sample or daily composite sample:

| | Tier II Limits | |
|-----------------------|---------------------------------|-----------------------------|
| Parameter | Limitation | Units |
| Arsenic (total) | 6.0000 <u>2.50</u> | mg/L |
| Cadmium (total) | 0.5000 <u>0.50</u> | mg/L |
| Chromium (total) | 21.0000 <u>21.00</u> | mg/L |
| Chromium (hexavalent) | 2.0000 | mg/L |
| Copper (total) | 100.0000 <u>22.00</u> | mg/L |
| Cyanide (total) | 0.2600 <u>0.26</u> | mg/L |
| Lead (total) | 39.0000 <u>18.00</u> | mg/L |
| Mercury (total) | $0.7000 \ 0.04$ | mg/L |
| Molybdenum (total) | <u>5.00</u> | mg/L |
| Nickel (total) | 5.0000 <u>5.00</u> | mg/L |
| Selenium (total) | 4.00 | $\underline{\mathrm{mg/L}}$ |
| Silver (total) | 5.0000 <u>5.00</u> | mg/L |
| Zinc (total) | 95.0000 <u>95.00</u> | mg/L |
| PCBs (total) | ND (not detectable) | mg/L |

SECTION 3. Severability. If any sentence, clause, section, or part of this Ordinance is for any reason found to be unconstitutional, illegal, or invalid, such unconstitutionality, illegality or invalidity shall not affect or impair any of the remaining provisions, sentences, clauses, sections, or parts hereof. It is hereby declared as the intent of the Board of Supervisors that this Ordinance would have been adopted had such unconstitutional, illegal, or invalid sentence, clause, section, or part thereof not been included herein.

SECTION 4. Repealer. All Ordinances, or parts of Ordinances, conflicting with any provisions of this Ordinance are hereby repealed insofar as the same affects this Ordinance.

SECTION 5. General Code. General Code is hereby authorized to make non-substantive formatting and numbering changes necessary to clarify references to other sections of the Easttown Township ordinances and/or codification and to bring the Ordinance into conformity with the Easttown Township ordinances/codification.

SECTION 6. Effective Date. This Ordinance shall be effective five days following enactment as by law provided.

[SIGNATURES ON THE FOLLOWING PAGE]



ATTEST:

DON CURLEY
Township Secretary

EASTTOWN TOWNSHIP BOARD OF SUPERVISORS

ERIK UNGER, Chair

MICHAEL WACEY, Vice Chair

SEAN AXEL, Member

ALEX BOSCO, Member

SUSAN LeBOUTILLIER, Member