

Application for Sidewalk Repair/Replacement Permit

- 1) Date of Application: ____ / ____ / ____

- 2) Site/Address _____ Indiana, PA _____ 15701
Street Address

- 3) Property Owner _____
Street Address City State Zip
Phone _____ Fax _____ Cell Phone _____
E-mail Address _____

- 4) Contractor _____
Address _____
Street Address City State Zip
Phone _____ Fax _____ Cell Phone _____
E-mail Address _____

- 5) Date of Proposed Repair/Replacement: _____

- 4) Location of Sidewalk: _____

- 5) Dimension of Sidewalk: _____
Length in feet Width in feet

- 6) Reason for Sidewalk Construction: _____

- 7) Additional Information: _____

- 8) Cost of Repair/Replacement: \$ _____

- 9) If applicable: Attach plans to scale, showing the actual shape and dimensions of the sidewalk and/or apron.

- 10) Attach (if not on file with the Borough) Workers Compensation Insurance Coverage and General Liability Insurance. If the applicant is self-employed and has no employees, the applicant must fill out and execute the Workers Compensation exemption form. The party required to have Workers Compensation Insurance shall provide the necessary insurance certificates in accordance with Section "b" of the Workers Compensation form.

_____ Applicant's Signature _____ Date

Office Personnel Use Only

Date Received: _____ Permit Number: _____

_____ Code Enforcement Officer _____ Date

SIDEWALK SPECIFICATIONS

1. Generally, the sidewalks must meet the minimum requirements established by the Indiana Borough sidewalk ordinance and other governing regulations (e.g. ADA requirements). Sidewalks must be a minimum of four (4) feet wide.
2. 3500# cement mix with fiber and C-grade fly-ash.
3. Two (2) rows of a minimum diameter of ½ inch re-bar must be installed and the length of the sidewalk with rebar cross braces tied a minimum of eight (8) feet along the length of the sidewalk to be poured.
4. When two (2) ends of rebar meet, they must overlap a minimum of 18 inches and tied at both ends.
5. Rebar chairs must be used to hold the two rows of rebar in the bottom third of the sidewalk being poured.
6. Expansion joints placed at all corner crossings, other sidewalks, driveways, and other fixed points.
7. A minimum of four (4) inches of 2B grade aggregate shall be placed under the concrete.
8. All sidewalks must be a minimum of four (4) inches thick. Driveway sections and all ADA compliant ramps must be a minimum of six (6) inches thick.
9. Truncated domes must be installed at sidewalks and intersecting streets.
10. Sidewalk must be sealed with a penetrating sealer.
11. After removal of the forms, the affected areas adjacent to the sidewalk must be filled with topsoil and seeded.
12. An inspection must be performed by the department of Planning & Code Enforcement after the form and prior to the pour.

Call 724-465-6543 to request an inspection. Please give a minimum of 24 hours' notice.

Thank You