

2023 Consumer Confidence Report

Annual Water Quality Report

If you have questions or concerns about your water call Town Hall at 307-367-4136, stop by Town Hall at 205 Entertainment Lane or attend a Town Council meeting held at 5:00 PM on the 2nd and 4th Monday of each month.



Our surface water assessment is available at the Pinedale Town Hall located at 205 Entertainment Lane

TOWN OF PINEDALE

205 Entertainment Lane
PO Box 709
Pinedale, WY 82941
307-367-4136

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by the Environmental Protection Agency (EPA). This report is a snapshot of last year's water quality. This report also contains important information on protecting Fremont Lake, our source water. That information is located on the last page of this report.

Where does my water come from and how is it treated?

Our source water consists of surface water drawn from an intake 120 feet below the surface of Fremont Lake. It is treated at our Fremont Lake Water Treatment Plant by the addition of chlorine to kill dangerous bacteria and microorganisms that may be in the water. The Town also uses UV



light disinfection to neutralize giardia, cryptosporidium, and other microorganisms that are resistant to chlorine disinfection. After the water travels from the treatment plant to the entry points of town, soda ash is added to help reduce water corrosion.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Español

Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

Water Quality Data Table

In order to ensure that tap water is safe to drink, the EPA prescribes regulations limiting the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although we tested for many more contaminants, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In the following table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions on the next page.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detected In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	21	NA	NA	2023	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	23	NA	NA	2023	No	By-product of drinking water disinfection
Inorganic Contaminants								
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	NA	NA	2023	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (optional) (ppm)	NA	NA	8.7	NA	NA	2023	No	Erosion of natural deposits; Leaching
Microbiological Contaminants								
E. coli (RTCR) - in the distribution system (positive samples)	0	0	0	NA	NA	2023	No	Human and animal fecal waste
Turbidity (NTU)	NA	5	0.40	NA	NA	2023	No	Soil runoff and sediment
Radioactive Contaminants								
Radium (combined 226/228) (pCi/L)	0	5	.9	NA	NA	2018	No	Erosion of natural deposits
Additional Contaminants		MCL	Your Water	Violation		Explanation and Comment		
Bromodichloromethane		None	1.2 ppb	No		Volatile Organic Compounds		
Chloroform		None	10 ppb	No		Volatile Organic Compounds		

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.03	2023	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Inorganic Contaminants							
Lead - action level at consumer taps (ppb)	0	15	1	2023	1	No	Corrosion of household plumbing systems; Erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NTU	NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of our raw water quality.
NA	NA: Not Applicable
ND	ND: Not Detected
NR	NR: Monitoring not required, but recommended.
positive samples	positive samples/yr: The number of positive samples taken that year.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pinedale Municipal Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

For more information please contact:

Spencer Hartman
Water/Wastewater Supervisor
PO Box 709
Pinedale, WY 82941
Phone: 307-367-2348

ATTENTION PROPERTY OWNERS
AND MANAGERS:
Please share this report with your tenants.

Find this report online at
www.townofpinedale.us

Scan for more
EPA Region 8
service line
inventory in-
formation.



Important Information: Lead and Copper Rule Service Line Inventory

This inventory is part of the Lead and Copper Rule Revisions from the EPA. All public water systems are required to complete an inventory of every water service line in the distribution system stating material, size, and installation date. This detailed spreadsheet is due to the EPA by October 16, 2024. It is also mandatory that the inventory be made publicly available upon completion.

Did you know?

- Lead in all plumbing materials was banned nationwide in 1988
- Most of the water service lines in the Town of Pinedale are copper. The main distribution lines are ductile iron.
- Water service lines connected to Town of Pinedale mains are customer owned.

You can help!

There are more than 1,000 service lines in the Town of Pinedale. If you recently replaced your service line or have specific information please email serviceline@townofpinedale.us. Include your physical address, any photos you may have, service line material, and a phone number.