

At the regularly scheduled public meeting of the Town Board of the Town of Rotterdam, held at the John F. Kirvin Government Center, 1100 Sunrise Boulevard, Rotterdam, New York 12306 on Wednesday, May 22, 2024, at 7:00 p.m., the following resolution was duly adopted:

RESOLUTION NO. 230.24

REVISIONS TO MERCURY LIMITS IN CHAPTER 230 SEWERS

WHEREAS, the Town Board recognizes the introduction of amendment to Chapter 230 of the Town Code; **NOW**

THEREFORE, UPON MOTION OF Councilmember **SCHLAG**, seconded by Councilmember **DODSON**,

BE IT RESOLVED BY THE TOWN BOARD AS FOLLOWS:

SECTION 1. The Town Board hereby determines that the proposed discharge standard modifications are a Type II action under the State Environmental Quality Review Act pursuant to 6 NYCRR § 617.5 (c) (26), and therefore no further SEQRA review is required.

SECTION 2. The Town Board of the Town of Rotterdam hereby adopts the revisions to the Mercury limits from 0.05 mg/L (50,000 ng/L) to 50 ng/Ls in accordance with the New York State Department of Environmental Conservation standards for effluent discharges from the Town of Rotterdam’s wastewater treatment plant.

SECTION 3. This resolution shall become effective May 22, 2024.

DATED: May 22, 2024

NAME	AYES	NOES	ABSTAIN
Dodson	X		
Mastroianni	X		
Gallucci	X		
Schlag	X		
Collins	X		

I, Diane M. Marco, Town Clerk of the Town of Rotterdam, Schenectady County, New York, **DO HEREBY CERTIFY** that the foregoing resolution was approved by the Town Board Meeting of the Town of Rotterdam on May 22, 2024, and that the foregoing resolution is a true and correct transcript of the original resolution and of the whole thereof and that said resolution is on file in the Town Clerk’s office.

I DO FURTHER CERTIFY that each of the members of the Town Board had due notice of the said Town Board meeting.

IN WITNESS WHEREOF, I have hereunto set my hand and the seal of the Town of Rotterdam this May 28, 2024.

Diane M. Marco

Diane M. Marco, Town Clerk



§ 230-37 Limitations.

A.

Concentration and pH limits.

(1)

No user shall discharge wastewater to the sanitary sewer system when any of the pollutant concentrations exceed the limits specified herein. These concentrations shall be applied to wastewater effluents at a point just prior to discharge into the Town's sewer system. With the express written consent of the Public Works Coordinator, users with multiple discharge outfalls may combine waste streams by calculation to report on wastewater characteristics.

Pollutant	Total Concentration Limit (mg/l)
Arsenic	0.2
Barium	4.0
BEHP	2.8
Beryllium	20
Cadmium	0.1
Chloroform	20
Chromium (hexavalent)	0.2
Chromium (total)	4.0
Copper	0.5
Cyanide	1.6
Lead	0.2
Mercury	0.05
Molybdenum	0.5
Nickel	3.5
Oil and grease	200
Phenols	4.0
Selenium	1.6
Silver	0.2
Zinc	2.0
	<u>(ng/l)</u>
Mercury	50

Formatted: Left, Indent: Left: 0"

Formatted: Left, Indent: Left: 0"