

ORDINANCE NO. 021

AN ORDINANCE AMENDING CHAPTER 179, NATURAL RESOURCES, CHAPTER 296, ZONING WITHIN PINELANDS AREA, AND CHAPTER 298, STORMWATER CONTROL WITHIN PINELANDS AREA, OF THE CODE OF THE TOWNSHIP OF WINSLOW, COUNTY OF CAMDEN AND STATE OF NEW JERSEY

WHEREAS, the Pinelands Protection Act (N.J.S.A. 13:18A-1) requires that the municipal master plan and local land use ordinances of the Township of Winslow implement the objectives of the Pinelands Comprehensive Management Plan (N.J.A.C. 7:50) and conform with the minimum standards contained therein; and

WHEREAS, the Pinelands Comprehensive Management Plan incorporates by reference certain stormwater management regulations contained at N.J.A.C. 7:8; and

WHEREAS, the New Jersey Department of Environmental Protection adopted amendments to certain stormwater management regulations contained at N.J.A.C. 7:8, effective July 17, 2023.

WHEREAS, the Pinelands Commission adopted amendments to the Pinelands Comprehensive Management Plan, effective December 4, 2023.

NOW, THEREFORE, BE IT ORDAINED by the Township Committee of the Township of Winslow, County of Camden and State of New Jersey, as follows:

SECTION 1: Chapter 298, Stormwater Control within Pinelands Area, Section 298-3, Stormwater Management Requirments, is hereby amended by repealing and replacing subsection D. with the following:

D. Tables 1, 2, and 3 below summarize the ability of stormwater best management practices identified and described in the New Jersey Stormwater BMP Manual to

satisfy the green infrastructure, groundwater recharge, stormwater runoff quality and stormwater runoff quantity standards specified in **§298-3N, O, P, and Q**. When designed in accordance with the most current version of the New Jersey Stormwater BMP Manual and this Section, the stormwater management measures found in **Tables 1, 2, and 3** are presumed to be capable of providing stormwater controls for the design and performance standards as outlined in the tables below. Upon amendments of the New Jersey Stormwater BMP Manual to reflect additions or deletions of BMPs meeting these standards, or changes in the presumed performance of BMPs designed in accordance with the New Jersey Stormwater BMP Manual, the NJDEP shall publish in the New Jersey Registers a notice of administrative change revising the applicable table. The most current version of the BMP Manual can be found on the NJDEP website at: <https://dep.nj.gov/stormwater/bmp-manual/>.

SECTION 2: Chapter 298, Stormwater Control within Pinelands Area, Section 298-3, Stormwater Management Requirments, is hereby amended by repealing and replacing subsections O.(2) and O.(3) with the following:

O. Groundwater Recharge Standards

- (2) For all major development, the total runoff volume generated from the net increase in impervious surfaces by the current 10-year, 24-hour storm, as defined and determined in **§298-4H**, shall be retained and infiltrated onsite.
- (3) For minor development that involves the construction of four or fewer dwelling units, the runoff generated from the total roof area of the dwelling(s) by the current 10-year, 24-hour storm, as defined and determined in **§298-4H**, shall be retained and infiltrated through installation of one or more green infrastructure stormwater management measures designed in accordance with the New Jersey Stormwater BMP Manual. Appropriate green infrastructure stormwater management measures include, but are not limited to dry wells, pervious pavement systems, and small scale bioretention systems, including rain gardens.

SECTION 3: Chapter 298, Stormwater Control within Pinelands Area, Section 298-3, Stormwater Management Requirments, is hereby amended by repealing and replacing subsections Q.(2)(a), Q.(2)(b) and Q.(2)(c) with the following:

Q. Stormwater Runoff Quantity Standards

- (2) In order to control stormwater runoff quantity impacts, the design engineer shall, using the assumptions and factors for stormwater runoff calculations at **§298-4**, complete one of the following:

- (a) Demonstrate through hydrologic and hydraulic analysis that for stormwater leaving the site, post-construction runoff hydrographs for the current and projected 2-, 10-, and 100-year storm events, as defined and determined in **§298-4H and I**, do not exceed, at any point in time, the pre-construction runoff hydrographs for the same storm events;
- (b) Demonstrate through hydrologic and hydraulic analysis that there is no increase, as compared to the pre-construction condition, in the peak runoff rates of stormwater leaving the site for the current and projected 2-, 10- and 100-year storm events, as defined and determined in **§298-4H and I**, and that the increased volume or change in timing of stormwater runoff will not increase flood damage at or downstream of the site. This analysis shall include the analysis of impacts of existing land uses and projected land uses assuming full development under existing zoning and land use ordinances in the drainage area;
- (c) Design stormwater management measures so that the post-construction peak runoff rates for the current and projected 2-, 10- and 100-year storm events, as defined and determined in **§298-4H and I**, are 50, 75 and 80 percent, respectively, of the pre-construction peak runoff rates. The percentages apply only to the post-construction stormwater runoff that is attributable to the portion of the site on which the proposed development or project is to be constructed; or

SECTION 4: Chapter 298, Stormwater Control within Pinelands Area, Section 298-4 A., C., H. and I., Calculation of Stormwater Runoff and Groundwater Recharge, is hereby amended by replacing A. & C. and adding H. & I. per the following:

§298-4. Calculation of Stormwater Runoff and Groundwater Recharge

- A. Stormwater runoff shall be calculated by the design engineer using the USDA Natural Resources Conservation Service (NRCS) methodology, including the NRCS Runoff Equation and Dimensionless Unit Hydrograph, as described in Chapters 7, 9, 10, 15 and 16 Part 630, Hydrology National Engineering Handbook, incorporated herein by reference as amended and supplemented, except that the Rational Method for peak flow and the Modified Rational Method for hydrograph computations shall not be used. This methodology is additionally described in Technical Release 55 - Urban Hydrology for Small Watersheds (TR-55), dated June 1986, incorporated herein by reference as amended and supplemented. Information regarding the methodology is available from the Natural Resources Conservation Service website at: <https://directives.sc.egov.usda.gov/ViewerFS.aspx?hid=21422> or at United States Department of Agriculture Natural Resources Conservation Service, New Jersey.

C. For the purpose of calculating curve numbers and groundwater recharge, there is a presumption that the pre-construction condition of a site or portion thereof is a wooded land use with good hydrologic condition. The term “curve number” applies to the NRCS methodology at A. above. A curve number or a groundwater recharge land cover for an existing condition may be used on all or a portion of the site if the design engineer verifies that the hydrologic condition has existed on the site or portion of the site for at least five years without interruption prior to the time of application. If more than one land cover has existed on the site during the five years immediately prior to the time of application, the land cover with the lowest runoff potential shall be used for the computations. In addition, there is the presumption that the site is in good hydrologic condition (if the land use type is pasture, lawn, or park), with good cover (if the land use type is woods), or with good hydrologic condition and conservation treatment (if the land use type is cultivation).

H. The precipitation depths of the current two-, 10-, and 100-year storm events shall be determined by multiplying the values determined in accordance with items (1) and (2) below:

- (1) The applicant shall utilize the National Oceanographic and Atmospheric Administration (NOAA), National Weather Service’s Atlas 14 Point Precipitation Frequency Estimates: NJ, in accordance with the location(s) of the drainage area(s) of the site. This data is available at:

https://hdsc.nws.noaa.gov/hdsc/pfds/pfds_map_cont.html?bkmrk=nj
or as updated by NOAA; and

- (2) The applicant shall utilize **Table 5: Current Precipitation Adjustment Factors** below, which sets forth the applicable multiplier for the drainage area(s) of the site, in accordance with the county or counties where the drainage area(s) of the site is located. Where the major development lies in more than one county, the precipitation values shall be adjusted according to the percentage of the drainage area in each county. Alternately, separate rainfall totals can be developed for each county using the values in the table below.

Table 5: Current Precipitation Adjustment Factors

County	Current Precipitation Adjustment Factors		
	<u>2-year Design Storm</u>	<u>10-year Design Storm</u>	<u>100-year Design Storm</u>
<u>Atlantic</u>	<u>1.01</u>	<u>1.02</u>	<u>1.03</u>
<u>Camden</u>	<u>1.03</u>	<u>1.04</u>	<u>1.05</u>
<u>Gloucester</u>	<u>1.05</u>	<u>1.06</u>	<u>1.06</u>

- I. Table 6:** Future Precipitation Change Factors provided below sets forth the change factors to be used in determining the projected two-, 10-, and 100-year storm events for use in this chapter, which are organized alphabetically by county. The precipitation depth of the projected two-, 10-, and 100-year storm events of a site shall be determined by multiplying the precipitation depth of the two-, 10-, and 100-year storm events determined from the National Weather Service’s Atlas 14 Point Precipitation Frequency Estimates pursuant to **H.(1)** above, by the change factor in the table below, in accordance with the county or counties where the drainage area(s) of the site is located. Where the major development and/or its drainage area lies in more than one county, the precipitation values shall be adjusted according to the percentage of the drainage area in each county. Alternately, separate rainfall totals can be developed for each county using the values in the table below.

Table 6: Future Precipitation Change Factors

<u>County</u>	<u>Future Precipitation Change Factors</u>		
	<u>2-year Design Storm</u>	<u>10-year Design Storm</u>	<u>100-year Design Storm</u>
<u>Atlantic</u>	<u>1.22</u>	<u>1.24</u>	<u>1.39</u>
<u>Camden</u>	<u>1.18</u>	<u>1.22</u>	<u>1.39</u>
<u>Gloucester</u>	<u>1.19</u>	<u>1.23</u>	<u>1.41</u>

SECTION 5: Chapter 298, Stormwater Control within Pinelands Area, Section 298-5 A.,

A.(2) and B.(1), Sources for Technical Guidance, is hereby repealed and replaced with the following:

§298-5. Sources for Technical Guidance

A. Technical guidance for stormwater management measures can be found in the documents listed below, which are available to download from the NJDEP’s website at: <https://dep.nj.gov/stormwater/bmp-manual/>.

(2) Additional maintenance guidance is available on the NJDEP’s website at: <https://dep.nj.gov/stormwater/maintenance-guidance/>.

B.

(1) Submissions required for review by the NJDEP should be mailed to:

The Division of Watershed Protection and Restoration, New Jersey Department of Environmental Protection, Mail Code 501-02A, PO Box 420, Trenton, New Jersey 08625-0420.

SECTION 6: Chapter 179, Natural Resources, Section 179-2, Definitions, is hereby amended by adding the following definition:

DIVERT or DIVERSION – Means the taking of water from a river, stream, lake, pond, aquifer, well, other underground source, or other waterbody, whether or not the water is returned thereto, consumed, made to flow into another stream or basin, or discharged elsewhere.

SECTION 7: Chapter 179, Natural Resources, Section 179-5, Application for permit, is hereby amended by adding subsection N.(19). as follows:

N. Any application filed for approval of resource extraction operations in the Pinelands Area shall also include the following information:

(19) If the application includes a proposed diversion from the Kirkwood-Cohansey aquifer, a hydrogeologic report that identifies the volume of the diversion, the volume of water to be returned to the source, a description of the route of return to the source, the methodology used to quantify the volume of water returned to the source and a description of any other existing or proposed water diversions or discharges on or from the parcel. The report shall also include a map that depicts the location of the diversion, the location of the return to source, the location of all existing or proposed resource extraction operations and the location of all wetlands on or within 300 feet of the parcel on which the diversion is proposed.

SECTION 8: Chapter 296, Zoning within Pinelands Area, Article I, General Provisions; Zoning Districts; Map; Definitions, Section 296-7, Definitions, is hereby amended by repealing and replacing subsection A. as follows:

A. Terms defined in the Pinelands Plan. The following certain terms, words or phrases used in this chapter which are peculiar to the standards and development regulations established by the Pinelands Commission are intended to have the meanings as defined in Section 2-201 of the Pinelands Comprehensive Management Plan (N.J.A.C. 7:50-2.11): agricultural employee housing; agricultural or horticultural purpose or use; agricultural products processing facilities; animals, threatened or endangered; building; camper; campsite; comprehensive management plan; contiguous land; density; divert or diversion; drainage; dwelling; dwelling unit; electric distribution lines; electric transmission lines; erosion; family; fire hazard; height; hydrologic unit code-11 or HUC-11;

immediate family; impermeable surface; institutional use; interested person or party; land; middle-income household; mobile home; navigable waters; nonconsumptive use; off-site commercial advertising sign; parcel; person; plants, threatened or endangered; preservation area; protection area; public development; recommended management practice; sign; solar energy facility; standard subsurface sewage disposal system; structural alteration; structure; subdivision; utility distribution line; and wetlands.

SECTION 9: Chapter 296, Zoning Within Pinelands Area, Article XV, Design and Performance Standards, Section 296-81, Stormwater and water management, is hereby amended by repealing and replacing subsection B. as follows:

B. Water Management.

(1) Water shall not be exported from the Pinelands except as otherwise provided at N.J.S.A. 58:1A-7.1.

(2) A diversion within the Pinelands Area portion of Winslow Township that involves the interbasin transfer of water from sources within the Pinelands Area between the Atlantic Basin and the Delaware Basin, as defined at **(a)** and **(b)** below, or outside of either basin, shall be prohibited.

(a) The Atlantic Basin is comprised of Watershed Management Areas 13, 14, 15, and 16, as identified by the New Jersey Department of Environmental Protection.

(b) The Delaware Basin is comprised of Watershed Management Areas 17, 18, 19, and 20 as identified by the New Jersey Department of Environmental Protection.

(3) A diversion within the Pinelands Area portion of Winslow Township involving the intrabasin transfer of water between HUC-11 watersheds in the same basin, Atlantic Basin or Delaware Basin as defined at **(2)(a)** and **(b)** above, shall be permitted. If such an intrabasin transfer involves water sourced from the Kirkwood-Cohansey aquifer, the diversion shall meet the criteria and standards set forth at **(4)** below.

(4) Within the Pinelands Area portion of Winslow Township a new diversion or an increase in allocation from either a single existing diversion source or from combined existing and new diversion sources in the same HUC-11 watershed and in the Kirkwood-Cohansey aquifer, that results in a total diversion of 50,000

gallons of water per day or more (hereafter referred to as "proposed diversion") shall meet the criteria and standards set forth at **(4)(c)** through **(f)** below and the water management standards of the Pinelands Comprehensive Management Plan at N.J.A.C. 7:50-6.86(d). "Allocation" shall mean a diversion permitted pursuant to a Water Allocation Permit or Water Use Registration Number issued by the New Jersey Department of Environmental Protection pursuant to N.J.A.C. 7:19.

(a) When evaluating whether the proposed diversion meets the criteria set forth at **(4)(c)** through **(f)** below, all of the applicant's allocations in an HUC-11 watershed, in addition to the proposed diversion, shall be included in the evaluation.

(b) The standards set forth at **(4)(c)** through **(f)** below shall not apply to:

[1] A new well that is to replace an existing well, provided the existing well is decommissioned in accordance with N.J.A.C. 7:9D-3 and the new replacement well will:

[a] Be approximately the same depth as the existing well;

[b] Divert from the same aquifer as the existing well;

[c] Have the same or lesser pump capacity as the existing well; and

[d] Be located within 100 feet of, and in the same HUC-11 watershed as, the existing well;

[2] Any proposed diversion that is exclusively for agricultural or horticultural use; or

[3] Any proposed diversion for a resource extraction operation that constitutes a nonconsumptive use, provided the water returned to the source is not discharged to a stream or waterbody or otherwise results in offsite flow, and the diversion and return are located on the same parcel.

(c) A proposed diversion shall be permitted only in the following Pinelands Management Areas: Regional Growth Area; Rural Development Area; Agricultural Production Area; and the Pinelands Villages of Blue Anchor, Elm, Tansboro, Waterford Works, and Winslow.

(d) A proposed diversion shall only be permitted if the applicant demonstrates that no alternative water supply source is available or viable. Alternative water supply sources include, but are not limited to, groundwater and surface water sources that are not part of the Kirkwood-Cohansey aquifer, and public water purveyors and suppliers, as defined at N.J.A.C. 7:19-1.3. A list of alternative

water supply sources is available at the offices of the Pinelands Commission and at <https://www.nj.gov/pinelands/>.

- (e) A proposed diversion shall not have an adverse ecological impact on the Kirkwood-Cohansey aquifer. Adverse ecological impact means an adverse regional impact and/or an adverse local impact, as described at N.J.A.C. 7:50-6.86(d)6 and 7, respectively. A proposed diversion deemed to have an adverse local impact in the Pinelands Area is prohibited. A proposed diversion deemed to have an adverse regional impact shall only be permitted if an applicant permanently offsets the diversion in accordance with N.J.A.C. 7:50-6.86(d)6i.
- (f) An applicant for a proposed diversion shall provide written documentation of water conservation measures that have been implemented, or that are planned for implementation, for all areas to be served by the proposed diversion. Water conservation measures are measurable efforts by public and private water system operators and local agencies to reduce water demand by users and reduce losses in the water distribution system.

SECTION 10: All ordinances or parts of ordinances inconsistent herewith are hereby repealed.

SECTION 11: If any section, subsection, sentence, clause, phrase or portion of this ordinance is for any reason held to be invalid or unconstitutional by a court of competent jurisdiction, such portion shall be deemed a separate, distinct and independent provision, and such holding shall not affect the validity of the remaining portions hereof.

SECTION 12: This ordinance shall take effect after second reading and publication as required by law and upon certification by the New Jersey Pinelands Commission.

INTRODUCED: June 25, 2024

ADOPTED: AUG 20 2024



Lisa L Dority, RMC
Municipal Clerk



Marie D. Lawrence, Mayor