

SUBDIVISION AND LAND DEVELOPMENT

305 Attachment 2

Borough of Old Forge

**Chart III
Borough Design Standards and Specifications for
Streets, Sidewalks and Right-of-Way Improvements
[Amended 10-21-2008 by Ord. No. 2008-3]**

Type of Street	Surface Pave		Base Pave		Subbase		Curb Type	Sidewalk Width (feet)
	Type	Depth (inches)	Type	Depth (inches)	Type	Depth (inches)		
Major	(Design in accordance with PA DOT standards and as approved by Borough Engineer)							
Collector	ID-2	1 1/2	BCBC	5	PA DOT	8	Concrete	5
Local	ID-2	1 1/2	BCBC	4	PA DOT	6	Concrete	4
Alley (nonresidential)	ID-2	1 1/2	BCBC	5	PA DOT	8	N/A	N/A

NOTES:

1. All materials, details and construction shall conform to PA DOT requirements, PA DOT Road Construction Standards (RC Standards) and PA DOT Publication 408 specifications, and any additional requirements provided within the Code of the Borough of Old Forge.
2. Subgrade shall be properly graded and compacted and must be inspected by the Borough Engineer prior to construction of the stone subbase.
3. Subbase and base pave must be inspected by the Borough Engineer prior to construction of the subsequent pave structure layer.
4. Curbs for alleys may be required in certain site situations to control storm drainage as required by the Old Forge Borough Council upon the recommendations of the Old Forge Borough Planning Commission and/or the Borough Engineer.
5. Sidewalks shall be concrete with a minimum thickness of four inches (five inches at drives) and shall be constructed on a crushed stone or aggregate base of a minimum four inches' thickness as per PA DOT requirements.