

AN ORDINANCE AMENDING APPENDIX B. "WATER MAIN SUPPLY PIPING, VALVES AND FITTINGS", SUBSECTION (C) (1) "WATER MAIN" OF THE MUNICIPAL CODE OF THE CITY OF WARRENTON, MISSOURI

BE IT ORDAINED BY THE BOARD OF ALDERMEN OF THE CITY OF WARRENTON, MISSOURI, AS FOLLOWS:

SECTION I. Subsection (1) "Water Main" of Appendix B. "Water Main Supply Piping, Valves and Fittings" of Chapter 530 of the Municipal Code, titled "Private Construction of Public Improvements" is hereby modified by amending certain sections of (1)(a) and (b) which shall read as follows:

APPENDIX B. WATER MAIN SUPPLY PIPING, VALVES AND FITTINGS

1. *Water main.*

- a. *Class 200 PVC water mains.* Water mains shall be a minimum of 8" PVC Class 200 pipe. Pipe shall conform to ASTM D2241 and shall be pressure rated at two hundred (200) psi at seventy-three degrees Fahrenheit (73°F) with a standard dimension ratio of SDR 21. PVC pipe must bear the seal of approval of the National Sanitation Foundation. Net laying lengths must be twenty (20) feet. Joints shall be integral bell push-on joints with single rubber gasket, making a pressure tight seal. Said pipe shall be in accordance with ANSI/ASTM D2241-78 or the latest revision thereof.
- b. *Ductile iron pipe.* Ductile iron pipe for use on water mains shall be a minimum of 8" pipe and under these specifications shall be cement-lined super bell-tite push-on joint manufactured of materials and methods meeting the tests set forth in 530 Attachment.

SECTION II. All ordinances or parts of ordinance in conflict with this Ordinance are hereby repealed.

SECTION III. This Ordinance shall take effect and be in full force from and after the passage and approval thereof.

READ TWO TIMES AND PASSED by the Board of Aldermen of the City of Warrenton, Missouri, this 2nd day of June, 2015.




President of the Board of Aldermen

APPROVED BY THE MAYOR of the City of Warrenton, Missouri this 2nd day of June,
2015.



Mayor

ATTEST:



City Clerk